

[Inside Home](#) [Find & Search](#) [People Finder](#)

PHA Findings

[PHA Database](#) | [PSM Home](#) | [LC, Seismic & ISS Findings](#)[PHA Search](#) | [PHA Results](#) | [Employee Feedback](#) | [Print this page](#) |

ABU	Plant	Revalidation	Start Date	End Date	Facilitator	Scribe
U&E	#1 POWER PLANT	2nd Revalidation	7/21/2004	7/27/2004	Steve Aakhus, AcuTech Consulting Group	Steve Aakhus

Core Team Members / Role Eric Raborn, Larry Savage, Rob Weiden	Close Out Meeting Participants / Role John Buchanan, Eric Raborn, Larry Savage, Rob Weiden
Additional Participants / Role	Entire PHA Report * Further discussion about any portion of the report and its contents should be directed to the facilitator or any of the team members listed
Comments	
Reviewed By Date Feedback/Comments	

Section No	Section Description										
57	General Issues.										
Item	WhatIf	Deviation	A/C	SOE		RR	ABU Proposal	Resolution	Owner	Due By	Status
57-11	16200	General Issues	Concern: The two PFDs available on the intranet were last updated in 1986. Consider updating the unit PFDs, or alternatively, locate training diagrams and evaluate whether they	0	5		Consider updating the unit PFDs, or alternatively, locate training diagrams and evaluate whether they satisfy the regulatory requirement for PFDs.	Please verify and sign off as complete. A hand drawn PFD has been created but has not been turned into an electronic drawing.	Raborn, Eric E.	4/1/2005	Declined

satisfy the regulatory requirement
for PFDs.

[Back to top](#)

Last Update: 4/10/2007
© 2001 - 2005 Chevron Corporation

Content Contact: Karen, Draper (KAMR)
Technical Contact: Pollepalli, Sanjeev (pols) Lee, Fred (FredWLee)

Company Confidential
Opco: Richmond Refinery